

KEMA TYPE TEST CERTIFICATE OF COMPLETE TYPE TESTS

was issued to

Nuhas Oman L.L.C.

Rusayl Industrial Estate, Oman

for the test object:

single-core

power cable

Type: 6,35/11 kV 1x500 mm² CU/XLPE/CTS/PVC/AWA/PVC Cable

Rating: 6,35/11 (12) kV - 1x500 mm² - Cu - XLPE

manufactured by

Nuhas Oman L.L.C.

Rusayl Industrial Estate, Oman

The test object has successfully passed the required type tests of

IEC 60502-2

The test results are recorded in Certificate No.

1358-18

This Certificate was issued on 24 September 2018.

DNV GL Netherlands B.V.



J.P. Fonteijne
Executive Vice President
KEMA Laboratories

