

TYPE TEST CERTIFICATE OF COMPLETE TYPE TEST**OBJECT** three-core power cable**TYPE** 2XCweTgY

Rated voltage, U_0/U (U_m)	8.7/15 (17.5) kV	Conductor material	Cu
Conductor cross-section	3x240 mm²	Insulation material	XLPE

MANUFACTURER Nuhas Oman L.L.C
Rusayl Industrial Estate, Sultanate of Oman**CLIENT** Nuhas Oman L.L.C
Rusayl Industrial Estate, Sultanate of Oman**TESTED BY** KEMA HIGH-VOLTAGE LABORATORY
Arnhem, the Netherlands**DATE OF TESTS** 16 April 2009 until 26 June 2009

The object, constructed in accordance with the description, drawings and photographs incorporated in this Certificate, has been subjected to the series of proving tests in accordance with

IEC 60502-2

This Type Test Certificate has been issued by KEMA following exclusively the STL Guides.

The results are shown in the record of Proving Tests and the oscillograms attached hereto. The values obtained and the general performance are considered to comply with the above Standard and to justify the ratings assigned by the manufacturer as listed on page 4.

This Certificate applies only to the object tested. The responsibility for conformity of any object having the same designations with that tested rests with the Manufacturer.

This Certificate consists of 36 pages in total.

© Copyright: Only integral reproduction of this Certificate is permitted without written permission from KEMA. Electronic copies in e.g. PDF-format or scanned version of this Certificate may be available and have the status "for information only".
The sealed and bound version of the Certificate is the only valid version.

KEMA Nederland B.V.


P.C.A. Bus
KEMA T&D Testing Services
Managing Director

Arnhem, 14 September 2009