

TEST CERTIFICATE

Issued to: Nuhas Oman L.L.C.
Plot no. 70, Road no.2,
P.O. Box 186, Post code 124
Rusayl Industrial Estate, Muscat, Oman

For the product: Multi-element metallic cables used in analogue and digital communication and control- Sectional specification for instrumentation and control cables

Trade name: NUHAS OMAN

Type/Model: CU/XLPE/IOSCR/PE/SWA/PVC 10p x 1,5 mm²

Ratings: 500 V

Manufactured by: Nuhas Oman L.L.C.
Plot no. 70, Road no.2,
P.O. Box 186, Post code 124
Rusayl Industrial Estate, Muscat, Oman

Requirements: EN 50288-1:2013 and EN 50288-7:2005

Remarks: The tested product meets the requirement.

This Test Certificate is granted on account of an examination by DEKRA, the results of which are laid down in a confidential file no 2185871.51.

The examination has been carried out on one single specimen of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Arnhem, 28 January 2016

Number: 2185871.01

DEKRA Certification B.V.



drs. G.J. Zoetbrood
Managing Director



H.R.M. Barends
Certification Manager

© Integral publication of this certificate and adjoining reports is allowed