

# TEST CERTIFICATE

Issued to: Nuhas Oman L.L.C.  
Road no.2, Plot no. 70  
Rusayl Industrial Estate  
PC -124 Muscat  
Oman

For the product: Flexible cable with cross-linked elastomeric insulation.

Trade name: NUHAS OMAN

Type/Model: H07RN-F 3C X 2.5 mm<sup>2</sup>

Manufactured by: Nuhas Oman L.L.C.  
Road no.2, Plot no. 70  
Rusayl Industrial Estate  
PC -124 Muscat  
Oman

Requirements: EN 50525-1:2011  
EN 50525-2-21:2011

Remarks: The tested cable meets the requirements.

The tested cable has been additional tested according to Annex D (Water resistance test for H07RN8-F flexible cables – Electrical test) and Annex E (Water resistance test for H07RN8-F flexible cables – Mechanical properties of sheath after water immersion).

This Test Certificate is granted on account of an examination by DEKRA, the results of which are laid down in a confidential file no 2257851.53-CAT.

The examination has been carried out on one single specimen of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Arnhem, 7 July 2022

Number: 2257851.03-DTC

DEKRA Certification B.V.

F.S. Strikwerda  
Certification Manager

© Integral publication of this certificate and adjoining reports is allowed