



TIC 1048-13

TYPE TEST CERTIFICATE OF COMPLETE TYPE TESTS

OBJECT Multi-core power cable

TYPE 0,6/1,0 kV, 4x120 mm², CU/XLPE/SWA/PVC

Rated voltage, U ₀ /U (U _m)	0,6/1,0 (1,2) kV	Conductor material	Cu
Conductor cross-section	4x120 mm ²	Insulation material	XLPE

MANUFACTURER Nuhas Oman L.L.C.,
Rusayl Industrial Estate, Sultanate of Oman

CLIENT Nuhas Oman L.L.C.,
Rusayl Industrial Estate, Sultanate of Oman

TESTED BY KEMA Nederland B.V.,
Arnhem, The Netherlands

DATE(S) OF TESTS 6 September to 4 October 2013

The object, constructed in accordance with the description, drawings and photographs incorporated in this Certificate, has been subjected to the series of proving tests in accordance with

BS 5467 (1997), including Amendment 3 (2008)

**The results are shown in the record of Proving Tests.
The values obtained and the general performance are considered to comply with the above Standard and to justify the ratings assigned by the manufacturer as listed on page 4 and 5.**

This certificate applies only to the object tested. The responsibility for conformity of any object having the same type and references as that tested rests with the manufacturer.

This Certificate consists of 24 pages in total.

Copyright: Only integral reproduction of this Certificate is permitted without written permission from KEMA. Electronic copies (e.g. PDF-format or scanned version of this Certificate) may be available and have the status "for information only". The printed and bound version of the Certificate is the only valid version.

KEMA Nederland B.V.

S.A.M. Verhoeven
Director Testing, Inspections &
Certification The Netherlands

Arnhem, 11 December 2013

