

**TYPE TEST CERTIFICATE OF COMPLETE TYPE TESTS****OBJECT** Multi-core power cable**TYPE** 0,6/1,0 kV, 4x120 mm<sup>2</sup>, CU/XLPE/SWA/PVC

<b>Rated voltage, U<sub>0</sub>/U (U<sub>m</sub>)</b>	<b>0,6/1,0 (1,2) kV</b>	<b>Conductor material</b>	<b>Cu</b>
<b>Conductor cross-section</b>	<b>4x120 mm<sup>2</sup></b>	<b>Insulation material</b>	<b>XLPE</b>

**MANUFACTURER** Nuhas Oman L.L.C.,  
Rusayl Industrial Estate, Sultanate of Oman**CLIENT** Nuhas Oman L.L.C.,  
Rusayl Industrial Estate, Sultanate of Oman**TESTED BY** KEMA Nederland B.V.,  
Arnhem, The Netherlands**DATE(S) OF TESTS** 6 September to 4 October 2013

The object, constructed in accordance with the description, drawings and photographs incorporated in this Certificate, has been subjected to the series of proving tests in accordance with

**IEC 60502-1** (2004), including Amendment 1 (2009)

**The results are shown in the record of Proving Tests.**

**The values obtained and the general performance are considered to comply with the above Standard and to justify the ratings assigned by the manufacturer as listed on page 4 and 5.**

This Certificate applies only to the object tested. The responsibility for conformity of any object having the same type references as that tested rests with the manufacturer.

This Certificate consists of 23 pages in total.

Copy note: Only integral reproduction of this Certificate is permitted without written permission from KEMA. Electronic copies, e.g. PDF-format or scanned version of this Certificate may be available and have the status "for information only". The sealed and bound version of the Certificate is the only valid version.

KEMA Nederland B.V.

S.A.M. Verhoeven  
Director Testing, Inspections &  
Certification The Netherlands

Arnhem, 16 December 2013