



TIC 1040-13

TYPE TEST CERTIFICATE OF COMPLETE TYPE TESTS

OBJECT Multi-core power cable

TYPE 0,6/1,0 kV, 4x300 mm², CU/XLPE/SWA/PVC

Rated voltage, U₀/U (U_m)	0,6/1,0 (1,2) kV	Conductor material	Cu
Conductor cross-section	4x300 mm²	Insulation material	XLPE

MANUFACTURER Nuhas Oman L.L.C.,
Rusayl, Sultanate of Oman

CLIENT Nuhas Oman L.L.C.,
Rusayl, Sultanate of Oman

TESTED BY KEMA Nederland B.V.,
Arnhem, The Netherlands

DATE(S) OF TESTS 13 August to 18 September 2013

The object, constructed in accordance with the description, drawings and photographs incorporated in this Certificate, has been subjected to the series of proving tests in accordance with

IEC 60502-1 (2004), including Amendment 1 (2009)

The results are shown in the record of Proving Tests.
The values of **and the general performance are considered to comply with the above**
Standards to justify the ratings assigned by the manufacturer as listed on page 4 and 5.

This Certificate applies only to the object tested. The responsibility for conformity of any object having the same type references as that tested rests with the manufacturer.

This Certificate consists of 23 pages in total.

Comment: Only integral reproduction of this Certificate is permitted without written permission from KEMA. Electronic copies, e.g. PDF-format or scanned version of this Certificate may be available and have the status "for information only". The sealed and bound version of the Certificate is the only valid version.

KEMA Nederland B.V.

S.A.M. Verhoeven
Director Testing, Inspections &
Certification The Netherlands

Arnhem, 16 December 2013

