

REPORT OF PERFORMANCE

TIC 1414-11 ✓


OBJECT	single-core power cable
TYPE	CU/XLPE/PVC 0,6/1kV, 1x800 mm ²
MANUFACTURER	Nuhas Oman LLC, Rusayl, Muscat, Oman
CLIENT	Nuhas Oman LLC, Rusayl, Muscat, Oman
TESTED BY	KEMA HIGH-VOLTAGE LABORATORY Arnhem, The Netherlands
DATE OF TESTS	13 January 2011 until 7 March 2011
TEST PROGRAMME	Type tests in accordance with IEC 60502-1 (2004) including Amendment 1 (2009) and BS 5467 (1997) including Amendment 3 (2008)
SUMMARY AND CONCLUSION	The object passed the tests.

This Report of Performance applies only to the object tested. The responsibility for conformity of any other object having the same designations with that tested rests with the Manufacturer.

This report consists of 29 pages in total.

© Copyright: Only integral reproduction of this report is permitted without written permission from KEMA. Electronic copies in e.g. PDF-format or scanned version of this report may be available and have the status "for information only".
The sealed and bound version of the report is the only valid version.

KEMA Nederland B.V.



S.K.M. Verhoeven
Director Testing, Inspections &
Certification The Netherlands

Arnhem, 23 June 2011