

TEST CERTIFICATE

Issued to: Nuhas Oman L.L.C.
Road no.2, Plot no. 70, Rusayl Industrial Estate, PC -124 Muscat, Oman

For the product: Power cables with XLPE insulation

Trade name: NUHAS OMAN

Tested cables: CU/XLPE/PVC/AWA/PVC 1x630 mm²
CU/XLPE/PVC/SWA/PVC 4x185 mm²
CU/XLPE/PVC/SWA/PVC 7x2,5 mm²

Covered range: **Single-core 600/1 000 V cable with copper conductor:**

CU/XLPE/PVC/AWA/PVC: 1x630 mm².

Multicore 600/1 000 V cable with copper conductors:

CU/XLPE/PVC/SWA/PVC: 2x1,5 mm ~ 2x400 mm²

CU/XLPE/PVC/SWA/PVC: 3x1,5 mm ~ 3x400 mm²

CU/XLPE/PVC/SWA/PVC: 4x1,5 mm ~ 4x400 mm²

CU/XLPE/PVC/SWA/PVC: 5x1,5 mm ~ 5x70 mm²

Multicore auxiliary 600/1 000 V cables with copper conductors:

CU/XLPE/PVC/SWA/PVC: 7x1,5 mm ~ 37x1,5 mm²

CU/XLPE/PVC/SWA/PVC: 7x2,5 mm ~ 37x2,5 mm²

CU/XLPE/PVC/SWA/PVC: 7x4,0 mm ~ 37x4,0 mm.

Ratings: 0,6/1kV

Manufactured by: Nuhas Oman L.L.C.
Road no.2, Plot no. 70, Rusayl Industrial Estate, PC -124 Muscat, Oman

Requirements: BS 5467:2016

Remarks: The tested cables meet the requirement.

This Test Certificate is granted on account of an examination by DEKRA, the results of which are laid down in a confidential test report nos. 2243961.54-CAT, 2243961.55-CAT, 2243961.56-CAT.

The examination has been carried out on one single specimen of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Arnhem, 29 April 2021

Number: 2243961.02-DTC

DEKRA Certification B.V.

F.S. Strikwerda
Certification Manager

© Integral publication of this certificate and adjoining reports is allowed