



TIC 1044-13

TYPE TEST CERTIFICATE OF COMPLETE TYPE TESTS

OBJECT Single core non-sheathed cable with thermoplastic PVC insulation

TYPE 450/750 V, 1x2,5 mm², CU/PVC, H07V-R

Rated voltage, U ₀ /U	450/750 V	Conductor material	Cu
Conductor cross-section	1x2,5 mm ²	Insulation material	PVC

MANUFACTURER Nuhas Oman L.L.C.,
Rusayl Industrial Estate, Sultanate of Oman

CLIENT Nuhas Oman L.L.C.,
Rusayl Industrial Estate, Sultanate of Oman

TESTED BY KEMA Nederland B.V.,
Arnhem, The Netherlands

DATE(S) OF TESTS 12 August to 25 September 2013

The object, constructed in accordance with the description, drawings and photographs incorporated in this Certificate, has been subjected to the series of proving tests in accordance with

BS EN 50525-2-31 (2011)

The results are shown in this document. The values obtained and the general performance are considered to comply with the above Standard and to justify the ratings assigned by the manufacturer as listed on page 4.

This Certificate applies only to the object tested. The responsibility for conformity of any object having the same type references as that tested rests with the manufacturer.

This Certificate consists of 20 pages in total.

Copyright: Only integral reproduction of this Certificate is permitted without written permission from KEMA. Electronic copies in e.g. PDF-format or scanned version of this Certificate may be available and have the status "for information only". The sealed and bound version of the Certificate is the only valid version.

KEMA Nederland B.V.

S.A.M. Verhoeven
Director Testing, Inspections &
Certification The Netherlands

Arnhem, 18 November 2013