

## **Declaration of Test Results**

BSI Product Services hereby declares that the item described below has been tested by BSI and complies with the requirements of BS 5308:Part 1:1986 Excluding Clause 14 spark test

The complete detail of the tests performed and the results are recorded in BSI Test Report No: 243/7342751 / 4 of 4 Dated: 25 August 2009

Description of item tested:

One sample of Electric Cable as follows;

12Px1.0 mm<sup>2</sup> Black colour sheath,

CU/PE/SWA/PVC with individual pair screens

Submitted by:

Nuhas Oman LLC

PO Box 186 Postal Code 124

Rusayl Industrial Estate

Sultanate of Oman

Declaration authorised by:

Title Laboratory Manager

Date 25 August 2009

Attention is drawn to the conditions upon which this declaration is issued, namely:

- This declaration does not indicate provide or imply any measure of Approval, Certification, Supervision, Control or Surveillance by BSI to this or any related product.
- This Declaration applied only to the particular sample tested and to the specific tests carried out as detailed in the Report referred to above.
- The general and specific conditions of the BSI Product Services, PS082 apply in all respects. Copies of this leaflet are available on request.