

KEMA TYPE TEST CERTIFICATE OF COMPLETE TYPE TESTS

was issued to

Nuhas Oman L.L.C.

Rusayl Industrial Estate, Oman

for the test object:

three-core

power cable

Type: 6,35/11 kV 3x240 mm² CU/XLPE/CTS/PVC/SWA/PVC Cable

Rating: 6,35/11 (12) kV - 3x240mm² - Cu - XLPE

manufactured by

Nuhas Oman L.L.C.

Rusayl Industrial Estate, Oman

The test object has successfully passed the required type tests of

IEC 60502-2

The test results are recorded in Certificate No.

1357-18

This Certificate was issued on 24 September 2018.

DNV GL Netherlands B.V.



J.P. Fonteijne
Executive Vice President
KEMA Laboratories

KEMA

Laboratories

© DNV GL

Please note that this document has been issued for information purposes only, and that the original bound and sealed paper copy of the Certificate including the results of the tests of the object will prevail. This document does not imply that DNV GL has certified or approved any object other than the specimen tested.

