TEST CERTIFICATE

Issued to:	Nuhas Oman L.L.C. Road no.2, Plot no. 70, Rusayl Industrial Estate PC -124 Muscat Oman
For the product:	Single core non-sheathed cable with thermoplastic PVC insulation
Trade name:	NUHAS OMAN
Tested cables:	CU/PVC (H07V-R) 1x2,5 mm² CU/PVC (H07V-R) 1x630 mm²
Covered range:	CU/PVC (H07V-R) 1x1,5 mm² ~ 1x630 mm²
Ratings:	450/750V
Manufactured by:	Nuhas Oman L.L.C. Road no.2, Plot no. 70, Rusayl Industrial Estate PC -124 Muscat Oman
Requirements:	BS EN 50525-1:2011 BS EN 50525-2-31:2011
Remarks:	The tested cables meet the requirement

This Test Certificate is granted on account of an examination by DEKRA, the results of which are laid down in a confidential test report nos. 2243961.59-CAT, 2243961.60-CAT.

The examination has been carried out on one single specimen of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Arnhem, 29 April 2021 Number: 2243961.05-DTC

DEKRA Certification B.V.

F.S. Strikwerda
Certification Manager

© Integral publication of this certificate and adjoining reports is allowed