

TEST CERTIFICATE

Issued to: Nuhas Oman L.L.C.
Road no.2, Plot no. 70, Rusayl Industrial Estate
PC -124 Muscat
Oman

For the product: Power cables with XLPE insulation having low emission of smoke and corrosive gases when affected by fire.

Trade name: NUHAS OMAN

Tested cable: CU/XLPE/LSOH/SWA/LSOH 4x185 mm²

Ratings: 0,6/1kV

Manufactured by: Nuhas Oman L.L.C.
Road no.2, Plot no. 70, Rusayl Industrial Estate
PC -124 Muscat
Oman

Requirements: BS 6724:2016

Remarks: The tested cable meets the requirement


This Test Certificate is granted on account of an examination by DEKRA, the results of which are laid down in a confidential test report no. 2243961.57-CAT.

The examination has been carried out on one single specimen of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Arnhem, 29 April 2021

Number: 2243961.03-DTC

DEKRA Certification B.V.



F.S. Strikwerda
Certification Manager

© Integral publication of this certificate and adjoining reports is allowed