



09-1058

TYPE TEST CERTIFICATE OF COMPLETE TYPE TEST

OBJECT three-core power cable

TYPE 2XCEPy2YYW2Y

Rated voltage, U₀/U (U_m)	6,35/11 (12) kV	Conductor material	Cu
Conductor cross-section	3x300 mm ²	Insulation material	XLPE

MANUFACTURER Nuhas Oman L.L.C.
Rusayl Industrial Estate, Sultanate of Oman

CLIENT Nuhas Oman L.L.C.
Rusayl Industrial Estate, Sultanate of Oman

TESTED BY KEMA HIGH-VOLTAGE LABORATORY
Arnhem, the Netherlands

DATE OF TESTS 12 August 2009 until 23 October 2009

The object, constructed in accordance with the description, drawings and photographs incorporated in this Certificate, has been subjected to the series of proving tests in accordance with

IEC 60502-2

This Type Test Certificate has been issued by KEMA following exclusively the STL Guides.

The results are shown in the record of Proving Tests and the oscillograms attached hereto. The values obtained and the general performance are considered to comply with the above Standard and to justify the ratings assigned by the manufacturer as listed on page 4.

This Certificate applies only to the object tested. The responsibility for conformity of any object with the same designations with that tested rests with the Manufacturer.

This Certificate consists of 47 pages in total.

© Copyright: Only integral reproduction of this Certificate is permitted without written permission from KEMA. Electronic copies in e.g. PDF-format or scanned version of this Certificate may be available and have the status "for information only". The sealed and bound version of the Certificate is the only valid version.

KEMA Nederland B.V.

P.G.A. Bus
KEMA T&D Testing Services
Managing Director
Arnhem, 30 March 2010

