

Certificate of Product Approval

Certificate Number: 1341a

Issue: 02

NUHAS OMAN L.L.C.

P.O. Box 186
Postal Code 124
Road No. 2
Plot No. 70
Rusayl Industrial Estate
Sultanate of Oman

is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirements of the standard(s) detailed below:

Product(s)

Cable Types as listed below:
FRC500 Cables

Standard(s) (see Appendix for details)

BS 7846:2015 Cat F2

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Obada Aljea

Signed for BRE Global Ltd.

Obada Piracha
Certification Scheme Manager

3 February 2021
Date of Issue

18 December 2015
Date of First issue



This certificate and appendix remain the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB® is a registered trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 1341a NUHAS OMAN L.L.C.

Issue: 02

Product name		LPCB Ref. No.
FRC500 Cables		1341a/01
Nominal csa of conductor (mm ²)	Core Construction	BS 7846
1.5	2, 3 & 4 ⁽¹⁾	F2 ⁽²⁾
2.5	2, 3 & 4 ⁽¹⁾	F2 ⁽²⁾
4.0	2, 3 & 4 ⁽¹⁾	F2 ⁽²⁾
6.0	2, 3 & 4 ⁽¹⁾	F2 ⁽²⁾
10	2, 3 & 4 ⁽¹⁾	F2 ⁽²⁾
16	2, 3 & 4 ⁽¹⁾	F2 ⁽²⁾
25	2, 3 & 4 ⁽¹⁾	F2 ⁽²⁾
35	2, 3 & 4 ⁽¹⁾	F2 ⁽²⁾
50	2, 3 & 4 ⁽¹⁾	F2 ⁽²⁾
70	2, 3 & 4 ⁽¹⁾	F2 ⁽²⁾
95	2, 3 & 4 ⁽¹⁾	F2 ⁽²⁾
120	2, 3 & 4 ⁽¹⁾	F2 ⁽²⁾

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Obada Aljea

Signed for BRE Global Ltd.

Obada Piracha
Certification Scheme Manager

3 February 2021
Date of Issue

18 December 2015
Date of First issue



This certificate and appendix remain the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a registered trademark of the Building Research Establishment Ltd.



bre

Appendix to Certificate No: 1341a NUHAS OMAN L.L.C.

Issue: 02

Product name		LPCB Ref. No.
FRC500 Cables		1341a/01
Nominal csa of conductor (mm ²)	Core Construction	BS 7846
150	2, 3 & 4 ⁽¹⁾	F2 ⁽²⁾
185	2, 3 & 4 ⁽¹⁾	F2 ⁽²⁾
240	2, 3 & 4 ⁽¹⁾	F2 ⁽²⁾
300	2, 3 & 4 ⁽¹⁾	F2 ⁽²⁾
400	2, 3 & 4 ⁽¹⁾	F2 ⁽²⁾

Uo/U 600/1000V

Notes:

1. Stranded conductors only.
2. In meeting the requirements to BS 7846:2015 Category F2, the FRC500 Cables listed met the requirements for smoke density of EN 61034-2, fire resistance requirements to BS 6387:2013 Categories CWZ and achieved less than 0.5%HCl for the insulation, tapes, bedding and outer covering when tested in accordance with EN 60754-1:2014.

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Obada Aljea

Signed for BRE Global Ltd.

Obada Piracha
Certification Scheme Manager

3 February 2021
Date of Issue

18 December 2015
Date of First issue



This certificate and appendix remain the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a registered trademark of the Building Research Establishment Ltd.

