

Certificate of Product Approval

Certificate Number: 1341b

Issue: 04

NUHAS OMAN L.L.C.

P.O. Box 186
 Postal Code 124
 Road No. 2
 Plot No. 70
 Rusayl Industrial Estate
 Sultanate Of Oman



is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirements of the standard(s) detailed below:

Product(s)

Cable Types as listed below:
 Fire Resistant Screened Cables FRC 300

Standard(s) (see Appendix for details)

BS 7629-1:2015 Standard 60
 EN 50200:2015 (Class PH120)
 EN 50200:2015 Annex E (30 mins)
 BS 5839-1:2013 (Clause 26.2d Standard)

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for BRE Global Ltd.

Karen Coull
 Certification Scheme Manager

3 July 2018
 Date of Issue

2 June 2016
 Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Garston, Watford, WD25 9XX
 T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB® is a registered trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 1341b NUHAS OMAN L.L.C.

Issue: 04

Product name				LPCB Ref. No.
Fire Resistant Screened Cables FRC 300				1341b/01
Nominal csa of conductor (mm ²)	Core Construction	BS 7629-1 See note 2	EN 50200	BS 5839-1 Clause 26.2d See note 3
1.0 ⁽¹⁾	2	Standard 60	PH120	Standard
1.5 ⁽¹⁾	2 & 3	Standard 60	PH120	Standard
2.5 ⁽¹⁾	2 & 3	Standard 60	PH120	Standard

Notes:

1. Solid conductor only.
2. In meeting the requirements of BS 7629-1:2015 Standard 60, the Fire Resistant Screened Cables FRC 300 listed met the requirements for smoke density of EN 61034-2:2005+A1:2013 and achieved less than 0.5% HCl for the outer covering & insulation when tested in accordance with EN 60754-1:2014.
3. The Fire Resistant Screened Cables FRC 300 listed conform to BS 7629-1:2015, met class PH 120 when tested in accordance with EN 50200:2015 and met the 30 mins duration when tested in accordance with EN 50200:2015 Annex E and hence met the requirements for a standard fire resistant cable as described in Clause 26.2d of BS 5839-1:2013.

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd.

Karen Coull
Certification Scheme Manager

3 July 2018
Date of Issue

2 June 2016
Date of First issue



This certificate and appendix remain the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a registered trademark of the Building Research Establishment Ltd.


