

TEST CERTIFICATE

Issued to: Nuhas Oman L.L.C.
Road no.2, Plot no. 70
Rusayl Industrial Estate
PC -124 Muscat
Oman

For the product: Flexible cable with cross-linked elastomeric insulation

Trade name: NUHAS OMAN

Type/Model: Tested cables: H07RN-F 1x300 mm²
H07RN-F 3G2,5 mm².

Covered range: 1x1,5 mm² - 1x630 mm²
2x1,0 mm² - 2x95 mm²
3x1,0 mm² - 3x300 mm²
4x1,0 mm² - 4x300 mm²

Ratings: 450/750 V

Manufactured by: Nuhas Oman L.L.C.
Road no.2, Plot no. 70
Rusayl Industrial Estate
PC -124 Muscat
Oman

Requirements: EN 50525-1:2011
EN 50525-1:2011/A1:2022
EN 50525-2-21:2011

Remarks: The tested cables meet the requirements

This Test Certificate is granted on account of an examination by DEKRA, the results of which are laid down in the DEKRA test reports nos. 2257851.53-CAT and 2285909.51-CAT.

The examination has been carried out on one single specimen of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of this production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Arnhem, 15 July 2024

Number: 2285909.01-DTC

DEKRA Certification B.V.



H.L. Schendstok
Certification Manager

© Integral publication of this certificate and adjoining reports is allowed.