

# UL TEST CERTIFICATE OF FIRE RESISTANCE

Certificate Number: UL TCNPF- 4790466722  
Page: 1/1  
Date of Issue: 2022-07-26

This Certificate provides the verification of all the specified rated characteristics of the product as specified by the manufacturer, by means of the performance of tests to verify the non-propagation of flame or fire resistance.

This Certificate shall only be considered valid when accompanied by the referenced Test Report(s) in full.

Issued to: **NUHAS OMAN LLC**  
Rusayl Industrial Estate, Plot No 70, RD No.2,  
PO Box 186, Muscat, PC 124, Oman

Manufacturer: **NUHAS OMAN LLC**  
Rusayl Industrial Estate, Plot No 70, RD No.2,  
PO Box 186, Muscat, PC 124, Oman

Manufacturing Site/Location: **NUHAS OMAN LLC**  
Rusayl Industrial Estate, Plot No 70, RD No.2,  
PO Box 186, Muscat, PC 124, Oman

Testing Location(s): **UL GmbH-Abu Dhabi Branch**  
Plot No. 106B-2, ICAD-I 12755, Abu Dhabi, UAE

Sample Description: **300/500 Volts, 2C X 1 mm<sup>2</sup>, Cu/SiR/SCR/LSOH**

Designation: **NUHAS OMAN FRC300 FIRE RESISTANT ELECTRIC CABLE, BS 7629-1**

Ratings: **300 / 500 Volts 2C X 1mm<sup>2</sup> BS 6387: 2013 Cat CWZ**

Test Procedure(s): **BS 6387: 2013 Clause 6, 7 & 8 (Protocol CWZ)**

Test Result(s): **The samples provided complied with the requirements specified in the standards mentioned under test procedure.**

Test Report Number(s): **4790404108-TR**

Additional Test Information: **Date of Tests: 25 May to 26 May, 2022**  
**The information LSOH mentioned under "Sample description" and BS 7629-1 mentioned under "Designation" are provided by NUHAS OMAN LLC. UL did not evaluate the cable to BS 7629-1 or for outer sheath properties related to Low Smoke and No Halogens.**

*Paul Knapp*

**Principal Engineering Manager  
Engineered Materials  
Wire & Cable  
Paul Knapp**

**Issuing Body UL Solutions**

Test results apply only to the sample(s) actually tested by UL. The client provided all of the test samples for testing by UL. UL did not select the samples or determine whether the samples provided were representative of other manufactured products. UL has not established Follow-Up Service or other surveillance of the product. The client and or manufacturer are solely and fully responsible for conformity of all products to all applicable standards, specifications, or requirements. UL Logo and Marks shall not be used in connection with the above certificate. This UL certificate does not indicate that the sample(s) of the product described herein has been investigated and found to have been in compliance with the entire standard(s) indicated on this certificate, nor does it indicate compliance with any UL certification program requirements.